

Spécialiste en Galvanisation / Galvanizing Specialist

Distributeur exclusif en Amérique du Nord, au Mexique, en Nouvelle-Zélande et en Australie Canadian exclusive master distributor for North America, Mexico, New Zealand and Australia

297 rue Gendron, C.P. 123, St-Léon-le-Grand, Qc, Canada GOJ 2W0 Téléphone / Phone: **418-743-2046** Sans frais / Toll free: **1-888-743-2046**

info@galvatech2000.com

galvatech2000.com



RUST-ANODE®

TECHNICAL DATA SHEET PRODUCT #300018B

Specially formulated for the maintenance of galvanized electrical transmission towers.

This Technology is formulated with a high zinc content, fast drying, and mono-component. It is ideal for a single application. Rust-Anode is a galvanizing compound designed for maximum corrosion protection with minimal surface preparation.

GENERAL INFORMATION

Evaluation by EPRI (Electric Power Research Institute) Aging performance, service life and evaluation of field applications

Hydro-Québec approval - TET-LIA- N-SUP0012 (Towers maintenance)

Hydro-Québec approval - SN31.101 (maintenance of electrical substations)

CFIA approval (The Canadian Food Inspection Agency)

High immersion resistance in fresh, salt, waste and saline environments (ASTM G44-99 (2013))

Single component designed to provide excellent performance in a single system

Applicable to a surface with non-friable rust

VOCs in accordance with California standards

Ease of application on site (Mitt,Roller,Brush,Gun)

Does not distort metals

Ability to be welded

Recoatable by itself at all times without abrasion

RECOMMENDED USE

Existing Transmissions and Telecommunication Towers
Hot-Dip Galvanized Refurbishment
Distribution Substation and Substation Infrastructure
Concrete Reinforcement Rebars*
Tower Legs and Anchors*

* Contact our technical support for an adapted procedure 1-888-743-2046					
STORAGE	HOMOLOGATIONS ET APPROBATIONS				
Keep in a dry area, between 5°C and 20°C (41°F to 68°F)	Hydro-Québec approval - SN31.101 (maintenance of electrical substations)				
Keep away from direct sun exposure	Hydro-Québec approval - TET-LIA- N-SUP0012 (Towers maintenance)				
Unopened pail shelf life: 48 months	CFIA approval (The Canadian Food Inspection Agency)				
Opened pail: Few months in standard storage conditions	Zinc-Rich Compound approved by the Canadian General Standards Board (CGSB)				
PACKAGING FORMAT	SAFETY				
12 kg (Format 5 liters / 1.3 US gallons)	Make sure that you understand and respect this technical data sheet, contact our customer service if necessary. Also consult the safety data sheet before use, contact us for the updated version				
(Solvent Suspension Fluide 5 liters)	Use adequate personal protective equipment in accordance with local regulations				

Drying and curing times Application of 7.0 mils (175 µm) wet

Application of 7.0 mils (175 μm) wet						
	35°F (1.7°C)	77°F (25°C)	100°F (38°C)	Zinc Quantity	96% (±2%) in the dry layer	
	50% relative humidity (RH)		ty (RH)	Zinc Purity	±99,995% purity	
Touch dry	30 minutes	20 minutes	15 minutes	Ready for use Single component		
Dry to handle	40 minutes	30 minutes	20 minutes	Colour	Matt gray RAL # 7001 (not colorable)	
To recoat Minimum	1 hour	1 hour	1 hour	Weight	Weight 3,15 Kg/dm ³ ± 0,1	
Maximum	unlimited	unlimited	unlimited	VOC (solvents)	340 grams / liter (± 10)	
The drying process varies depending on temperature and humidity				Flash point	29°C (84,2°F)	
				Solvent	Suspension Fluide Orange® (#300025)	
Relative humidity during the application and drying: maximum 90%				See below for other performance characteristics		

thickness	Between 6 and 10 mils (150μm and 250μm) wet depending on substrate	<u>Test name</u>	<u>Standard</u>	Rust-Anode®	Hot-dip Galvanized	
	condition.			Evaluated by ASTM D 610 (rust) and ASTM D714 (blister)		
	Contact our technical support before use to obtain our adapted procedure.	Cyclic Corrosion 10,000 hours	ASTM D5894-10	Rust: Few	Rust: None	
Performances in	rformances in		(cold periods)	Blister: None	Blister: None	
hot and cold weather	From -62°C to +120°C (-80°F to +250°F)	Immersion corrosion (salt water) Results at 90 days	ASTM G44-99 (2013) Sodium chloride 3.5%	Rust: <0,01%	Rust: 33%	
Application temperature	From -5 °C to +37 °C (23 °F to +98 °F) The curing time may vary depending on the ambient temperature.			Blister: None	Bliste: None	
		Steel samples used for tests Surface preparation: SSPC-SP10 / NACE 2 / SA 2.5 Products testel: Rust-Anode® versus Hot Dip Galvanization				
(substrate)	The temperature of the substrate to be treated must be a minimum of 3°C (5°F) above the dew point.	Application of a single coat of Rust-Anode® Primer without any paint coating				
Estimated performance	With the same benefits as hot-dip galvanizing when properly applied. Reference -EPRI Report	Test name	<u>Standard</u>	<u>Rust-Anode®</u>		
Resistance in salt water and	High level of resistance	Organic zinc rich	ONGC -1,181/CAN/ CGSB-1.181-92	Conform		
fresh water	See performance tests ASTM G44-99(2013)	Adhesion	ASTM D3359	5B		
		Flexibility - Folding -	ASTM D522, tapered	No Craks		
Resitance to Acids / Bases	PH of 5,5 to 9	Plasticity	mandrel 1/4, 180°	No blistering		
		UV	ASTM G154-12a	Little effect		
High	No cracking – Allows the dilatation of the metallic support when bent. See tests performances	Salt Spray	ASTM B117/ ISO 12944-6/7253	No Craks No blistering		
plasticity	ASTM D522, tapered mandrel 1/4, 180°	Cathodic detachment	ASTM G8-96(2010)	Pass		
THEORETICAL COVERAGE		Cathodic protection	ASTM G215-17	Same as hot	-dip galvanized	
At 1 mil (25μm) dry «899 Pi² / 12Kg or 84m² / 12kg»		Weldability	A thin layer can be welded without contaminating the welds (X-ray)			
ASTM D2697 - Dry extract by volume 54,8%			(40μm or 1.5 mils dry)			
Consult our calculation of required pails (for information only) Consult our theoretical coverage guide (for information only)		Conductivity	The wet film has excellent conductivity			
consult out theoretical coverage gaine from morning only)						

GENERAL CONDITIONS FOR SURFACE PREPARATION

The surface must be clean; free of brittle material and / or rust, flash rust, corrosion (black iron oxide), grease, cutting fluids or other visible and non-visible contaminants

The sharp edges as well as the drill holes should be chamfered. Prioritize continuous weld beads

If traces of black iron oxide (corrosion) are present, they must clean to bare metal

When cleaning surfaces, do not use Suspension Fluid, Varsol, Turpentine and/or other products that leave a residual factor on the surfaces. Acetone or MEK are approved

Then perform the recommended surface preparation

Surface preparation methods are not limited to our recommendations

VISIBLE AND NON-VISIBLE CONTAMINANTS DECONTAMINATION

In the presence of a potentially and geographically saline environment, tests must be carried out and the salts must be removed

The presence of salts must be less than 7μg/cm²

If necessary, the CHLOR-RID or HOLDTIGH product must be used and all other products must be approved in writing by Galvatech 2000.

Observe the manufacturer's recommendations for dilution

Contaminants shall be eliminated before the surface preparation. Then perform the recommended surface preparation

Surface preparation methods are not limited to our recommendations

NEW AND EXISTING STEEL

(SSPC-SP2) Hand tool, friable material and millscale must be removed completely.

(SSPC-SP3) Power tool cleaning - Shall be free of all loose materials. Counter to this specification all mill scale shall be removed

(SSPC-SP6 / NACE 3) Commercial blast cleaning

NEW HOT-DIP GALVANIZING

(SSPC-SP1) Solvent degreasing to remove all traces of oil, grease or any other contaminant

(SSPC-SP2) Cleaning with non-mechanical tools. (Stainless steel brush)

(SSPC-SP3) Cleaning with power tools

(SSPC-SP16) The surface must be free of oil, grease, passivating treatment or other contamination.

For freshly galvanized surfaces (0-1 year) check for the presence of passivating treatments during galvanization (e.g. chromate): «Chromium plating» refers to the treatment of galvanized parts to prevent the appearance of wet storage stains. The presence of chromates or other passivating treatments is detected using a copper sulphate solution. (SSPC-SP16)

Surface preparation methods are not limited to our recommendations

Contact our technical support before application for an adapted procedure 1-888-743-2046

PREPARATION ON AN EXISTING HOT-DIP GALVANIZING OR METALLIZING

The surface shall be free of rust dust, friable material, oils, grease or other contaminants, including surface salts and the presence of zinc oxide in white powder or crust

(SSPC-SP1) Solvent degreasing to remove all traces of oil, grease or any other contaminant

(SSPC-SP2) Cleaning with non-mechanical tools. (Stainless steel brush)

(SSPC-SP3) Cleaning with power tools

(SSPC-SP16) The surface must be free of oil, grease, passivating treatment or other contamination.

Surface preparation methods are not limited to our recommendations

Contact our technical support before application for an adapted procedure 1-888-743-2046

PREPARATION OF A SURFACE WITH AN EXISTING PAINT

The surface must be free of rust dust, friable material, oil, grease or other contaminants

Adhesion testing shall be performed on the paint remaining after cleaning. (ASTM D6677)

Perform an application on a small area to ensure product compatibility

Never apply on bituminous coatings and aluminium paints

We recommend removing at least 50% of the existing paint to obtain adequate protection

Surface preparation methods are not limited to our recommendations

Contact our technical support before application for an adapted procedure 1-888-743-2046

APPLICATION METHODS - GENERAL INFORMATION

The product is ready to use for application, open the pail and mix at low speed until completely homogenized, do not use an automatic paint shaker.

Apply a stripe coat with a paintbrush on the welds, bolts, edges, hard to reach areas, and around of the interface plates, etc.

Brush, mitt or spray application between 9 and 13 mils (225μm and 325μm) wet depending on substrate condition.

Rough surfaces, caused by surface preparation to remove corrosion, may require a compensating thicker layer.

No dilution is necessary, however it can be diluted with Suspension Fluide to ease the application. (20% maximum dilution)

The use of a wet film thickness gauge is required.

Excess thickness could increase drying time and is not recommended.

TOUCH-UP (facilities or/and on site)

At all times, if touch-ups are necessary, remove the contaminants then apply a generous coat with a paintbrush or a roller and/or a paint gun to, at least, reaching the same thickness. as the surrounding layer

NOTE

In the case of project or particular conditions, these data can be adapted, contact our technical support 1 888 743-2046 or by e-mail at info@galvatech2000.com

AVERTISSEMENTS

It is imperative that only Orange® Suspension Fluid (#300025) be used as a diluent. Any other product used may cause an adverse effect on the chemical composition of the product. On the other hand, painting equipment can be cleaned with a paint solvent, as long as it does not leave greasy substances and as long as it is well drained.

The information contained in this document is not exhaustive. Ensure to also consult the material safety data sheet of the product as well as to follow any application protocol or other specific instructions that may be issued by Galvatech. Anyone using the product in a manner other than that recommended (without prior written confirmation from Galvatech as to the suitability of the intended method of use), is being exposed to damage to properties or persons and does so at his own risk. All our recommendations or product statements are correct to the best of our knowledge, but Galvatech cannot guarantee neither the quality or condition of the application surface nor the other factors in the use and application of this product that may affect its performance. Accordingly, unless confirmed in writing by Galvatech, any warranty as to the performance of the product or the achievement of specific results is expressly excluded. Galvatech will not be liable for any loss or damage incurred in connection with storage or use of the product not in accordance with the instructions issued by Galvatech. All other warranties or representations, express or implied, by law or otherwise, including, without limitation, any implied warranties of merchantability or fitness for a particular purpose, are hereby expressly excluded. The information contained in this document is subject to change based on the evolving knowledge of the product and any improvement thereof. It is the responsibility of the user to check with a representative of Galvatech that it has the current version of this technical data sheet before using the product. All sales are subject to our terms and conditions of sale, available on our website at galvatech2000.com.

